

# Single-Phase Residential Electrical System Inspection Checklist

InterNACHI Standards · NEC 2023 References · Field-Ready Format

Inspector Name: _____ ---	License #: _____
Property Address: _____ ---	Inspection Date: _____
Client Name: _____ ---	Panel MFG/Age: _____
Service Size (Amps): _____ ---	Meter #: _____

Legend:     P = Pass / Acceptable     F = Fail / Defect Found     NA = Not Applicable    NEC Ref = Code Citation    [photo] = Photo Required

**1 SERVICE ENTRANCE & METER BASE** PASS   FAIL   N/A  
NEC Art. 230 | InterNACHI Std. 3.7

- |   |               |                            |                            |                             |
|---|---------------|----------------------------|----------------------------|-----------------------------|
| <input type="checkbox"/> Service drop attachment point — secured, weatherhead intact          | NEC 230.54    | <input type="checkbox"/> P | <input type="checkbox"/> F | <input type="checkbox"/> NA |
| <input type="checkbox"/> Drip loops present on service entrance conductors                    | NEC 230.54(F) | <input type="checkbox"/> P | <input type="checkbox"/> F | <input type="checkbox"/> NA |
| <input type="checkbox"/> Service entrance cable (SEC) — no damage, cracking, or deterioration | NEC 230.40    | <input type="checkbox"/> P | <input type="checkbox"/> F | <input type="checkbox"/> NA |
| <input type="checkbox"/> Service entrance conductors properly sized for service ampacity      | NEC 230.42    | <input type="checkbox"/> P | <input type="checkbox"/> F | <input type="checkbox"/> NA |
| <input type="checkbox"/> Weatherhead minimum 10 ft above grade (12 ft over driveways)         | NEC 230.24    | <input type="checkbox"/> P | <input type="checkbox"/> F | <input type="checkbox"/> NA |
| <input type="checkbox"/> Service entrance cable secured within 12 in. of meter/panel          | NEC 230.51    | <input type="checkbox"/> P | <input type="checkbox"/> F | <input type="checkbox"/> NA |
| <input type="checkbox"/> Meter base — secure, no corrosion, proper enclosure                  | NEC 230.66    | <input type="checkbox"/> P | <input type="checkbox"/> F | <input type="checkbox"/> NA |
| <input type="checkbox"/> Meter socket rated appropriately for service ampacity                |               | <input type="checkbox"/> P | <input type="checkbox"/> F | <input type="checkbox"/> NA |
| <input type="checkbox"/> Conduit/raceway — no open knockouts, weatherproofed entry            | NEC 230.52    | <input type="checkbox"/> P | <input type="checkbox"/> F | <input type="checkbox"/> NA |
| <input type="checkbox"/> Service conductors not in contact with siding or combustibles        | NEC 230.50    | <input type="checkbox"/> P | <input type="checkbox"/> F | <input type="checkbox"/> NA |
| <input type="checkbox"/> Clearances from windows, doors, porches met (3 ft min.)              | NEC 230.9     | <input type="checkbox"/> P | <input type="checkbox"/> F | <input type="checkbox"/> NA |
| <input type="checkbox"/> Service disconnect accessible, identified, within building reach     | NEC 230.70    | <input type="checkbox"/> P | <input type="checkbox"/> F | <input type="checkbox"/> NA |

Section 1 Notes / Photo Reference:

---



---



---

Photo #

2

## MAIN SERVICE PANEL

NEC Art. 408, 230, 240 | InterNACHI Std. 3.7

PASS FAIL N/A

## 2A — PANEL LABELING &amp; IDENTIFICATION

<input type="checkbox"/> All breakers clearly labeled, legible, accurate	NEC 408.4	P	F	NA
<input type="checkbox"/> Directory card present in panel door, up-to-date	NEC 408.4(A)	P	F	NA
<input type="checkbox"/> Panel manufacturer, ampacity, voltage rating visible	NEC 110.21	P	F	NA
<input type="checkbox"/> Panel cover present and properly secured	NEC 408.18	P	F	NA
<input type="checkbox"/> No open knockouts in panel enclosure	NEC 408.7	P	F	NA

## 2B — BREAKERS &amp; OVERCURRENT PROTECTION

<input type="checkbox"/> Main breaker rated correctly for service ampacity (100A / 150A / 200A)	NEC 230.79	P	F	NA
<input type="checkbox"/> No double-tapped breakers (unless listed for multi-wire)	NEC 408.36	P	F	NA
<input type="checkbox"/> No tandem/duplex breakers in non-listed positions	NEC 240.8	P	F	NA
<input type="checkbox"/> Breakers properly sized for conductor ampacity	NEC 240.4	P	F	NA
<input type="checkbox"/> 240V circuits using two-pole breakers (not two singles tied)	NEC 240.20(B)	P	F	NA
<input type="checkbox"/> No exposed live parts accessible without tools	NEC 110.27	P	F	NA
<input type="checkbox"/> Breakers trip freely and reset properly (spot check)	NEC 110.12	P	F	NA
<input type="checkbox"/> No signs of overheating — scorch marks, melted insulation, odor	NEC 110.12	P	F	NA
<input type="checkbox"/> AFCI breakers installed where required (bedrooms, living areas)	NEC 210.12	P	F	NA
<input type="checkbox"/> GFCI breakers installed where required (bath, garage, exterior, kitchen)	NEC 210.8	P	F	NA

## 2C — BUSBARS, CONDUCTORS &amp; WIRING

<input type="checkbox"/> Neutral (grounded) conductors connected to neutral bar only	NEC 408.40	P	F	NA
<input type="checkbox"/> Equipment grounding conductors on ground bar only	NEC 408.40	P	F	NA
<input type="checkbox"/> Neutral and ground bars bonded at service (main panel only)	NEC 250.28	P	F	NA
<input type="checkbox"/> Neutral/ground bars NOT bonded in sub-panels	NEC 250.142	P	F	NA
<input type="checkbox"/> Conductors properly sized, no visible damage or splices	NEC 310.15	P	F	NA
<input type="checkbox"/> Service entrance neutral — insulated or properly identified	NEC 230.41	P	F	NA
<input type="checkbox"/> Aluminum wiring — anti-oxidant compound at connections if present	NEC 110.14	P	F	NA

## 2D — WORKING CLEARANCES

<input type="checkbox"/> Minimum 36 in. clearance in front of panel (working space)	NEC 110.26(A)	P	F	NA
<input type="checkbox"/> Minimum 30 in. wide working space (or panel width if wider)	NEC 110.26(A)(2)	P	F	NA

- Minimum 6.5 ft. headroom in front of panel NEC 110.26(A)(3)  P  F  NA
- Panel not located in closets, bathrooms, or storage spaces NEC 240.24(D)(E)  P  F  NA
- Panel accessible without moving stored materials NEC 240.24(A)  P  F  NA

[!] FPE STAB-LOK / ZINSCO PANELS – If identified, document immediately as a SAFETY HAZARD. FPE Stab-Lok panels have a well-documented history of breaker failure to trip on overcurrent. Zinsco (GTE-Sylvania) panels similarly fail to interrupt fault current. Recommend evaluation and replacement by licensed electrician.

2E – FPE / ZINSCO IDENTIFICATION

- Panel manufacturer identified – NOT FPE Stab-Lok or Zinsco  P  F  NA
- If FPE/Zinsco present – documented as safety deficiency  P  F  NA
- If FPE/Zinsco – electrician evaluation recommended in report  P  F  NA

Section 2 Notes / Photo Reference (panel photos essential):

Photo #

**3 GROUNDING & BONDING**  
NEC Art. 250 | InterNACHI Std. 3.7.6

PASS FAIL N/A

3A – GROUNDING ELECTRODES

- Grounding electrode system present and accessible for inspection NEC 250.50  P  F  NA
- Ground rod(s) – min. 8 ft driven, accessible upper end NEC 250.52(A)(5)  P  F  NA
- Two ground rods used if single rod > 25 ohms resistance NEC 250.53(A)(2)  P  F  NA
- Ground rod conductor – min. #6 AWG copper (200A service) NEC 250.66  P  F  NA
- Concrete-encased electrode (Ufer ground) present if slab construction NEC 250.52(A)(3)  P  F  NA
- Water pipe electrode bonded if metallic water pipe present NEC 250.52(A)(1)  P  F  NA
- Ground electrode conductor protected from physical damage NEC 250.64  P  F  NA
- GEC connections – irreversible clamps or exothermic welds NEC 250.70  P  F  NA
- No splices in GEC (unless irreversible connector used) NEC 250.64(C)  P  F  NA

3B – WATER & GAS PIPE BONDING

- Metal water pipe bonded within 5 ft of entry (or at meter) NEC 250.52(A)(1)  P  F  NA
- Metal gas piping bonded to electrical grounding system NEC 250.104(B)  P  F  NA
- Bonding jumper around water meter (if meter could be removed) NEC 250.53(D)(1)  P  F  NA
- Structural steel bonded if used as electrode NEC 250.52(A)(2)  P  F  NA

CSST gas piping — bonding clamp present (per AGA IFGC) IFGC 310.1.1  P  F  NA

3C — EQUIPMENT GROUNDING

Equipment grounding conductors present in circuits NEC 250.118  P  F  NA

Metal conduit/boxes properly grounded (continuity) NEC 250.86  P  F  NA

Grounding conductor size matches circuit conductors NEC 250.122  P  F  NA

Section 3 Notes / Photo Reference:

Photo #

4

**BRANCH CIRCUITS & WIRING**

NEC Art. 210, 334, 336 | InterNACHI Std. 3.7

PASS  FAIL  N/A

4A — ROUGH-IN REQUIREMENTS

Minimum 15A circuits for general lighting/receptacles NEC 210.11(A)  P  F  NA

Small appliance circuits (2 min.) — 20A in kitchen NEC 210.11(C)(1)  P  F  NA

Laundry circuit — individual 20A circuit present NEC 210.11(C)(2)  P  F  NA

Bathroom circuit — individual 20A circuit (or whole-house bath) NEC 210.11(C)(3)  P  F  NA

Garage circuit separate (GFCI protected) NEC 210.8(A)(2)  P  F  NA

Outdoor receptacle circuit GFCI protected NEC 210.8(A)(3)  P  F  NA

Circuits not overloaded — max. 80% continuous load NEC 210.19(A)(1)  P  F  NA

Multi-wire branch circuits (MWBC) — handle-tied or 2-pole breaker NEC 210.4(B)  P  F  NA

MWBC neutrals — separate conductors, not shared on one terminal NEC 408.41  P  F  NA

4B — WIRING SUPPORT & INSTALLATION

NM cable supported every 4.5 ft and within 12 in. of boxes NEC 334.30  P  F  NA

NM cable not stapled through — only alongside NEC 334.17  P  F  NA

NM cable protected in conduit through studs at low height NEC 334.15  P  F  NA

Cable not kinked, pinched, abraded, or damaged NEC 334.24  P  F  NA

Exposed wiring in unfinished areas properly protected NEC 334.15  P  F  NA

Wiring method appropriate for location (wet, damp, dry) NEC 310.10  P  F  NA

Aluminum branch circuit wiring — CO/ALR devices only NEC 110.14  P  F  NA

4C — PHYSICAL PROTECTION

Nail plates installed where cable passes through studs < 1.25 in. from edge NEC 300.4(A)  P  F  NA

<input type="checkbox"/> Nail plates installed where cable passes through joists < 1.25 in. from edge	NEC 300.4(A)	P	F	NA
<input type="checkbox"/> Underground feeder (UF) cable properly buried (12-24 in. depth)	NEC 300.5	P	F	NA
<input type="checkbox"/> Conduit — proper type for location (EMT, rigid, PVC)	NEC 358/344/352	P	F	NA
<input type="checkbox"/> Junction boxes accessible, covered with blank cover plates	NEC 314.29	P	F	NA
<input type="checkbox"/> Boxes filled properly — no overfill (fill calc applied)	NEC 314.16	P	F	NA

Section 4 Notes / Photo Reference:

Photo #

5

RECEPTACLES & OUTLETS

NEC Art. 210.8, 210.11, 210.52 | InterNACHI Std. 3.7

PASS FAIL N/A

5A — GFCI PROTECTION (REQUIRED LOCATIONS)

<input type="checkbox"/> Kitchen countertop receptacles — GFCI protected (within 6 ft of sink)	NEC 210.8(A)(6)	P	F	NA
<input type="checkbox"/> Bathrooms — all receptacles GFCI protected	NEC 210.8(A)(1)	P	F	NA
<input type="checkbox"/> Garage — all 125V receptacles GFCI protected	NEC 210.8(A)(2)	P	F	NA
<input type="checkbox"/> Exterior receptacles — GFCI protected	NEC 210.8(A)(3)	P	F	NA
<input type="checkbox"/> Crawlspace receptacles — GFCI protected	NEC 210.8(A)(4)	P	F	NA
<input type="checkbox"/> Unfinished basements — GFCI protected	NEC 210.8(A)(5)	P	F	NA
<input type="checkbox"/> Within 6 ft of laundry/utility sinks — GFCI protected	NEC 210.8(A)(7)	P	F	NA
<input type="checkbox"/> Boathouses and pool areas — GFCI protected	NEC 210.8(A)(9)	P	F	NA
<input type="checkbox"/> GFCI devices test and reset properly (tested with tester)	NEC 406.4(D)(3)	P	F	NA

5B — AFCI PROTECTION (REQUIRED LOCATIONS)

<input type="checkbox"/> Bedrooms — AFCI protection (all 120V, 15/20A circuits)	NEC 210.12(A)	P	F	NA
<input type="checkbox"/> Living rooms, parlors, libraries — AFCI protected	NEC 210.12(A)	P	F	NA
<input type="checkbox"/> Dining rooms, family rooms — AFCI protected	NEC 210.12(A)	P	F	NA
<input type="checkbox"/> Hallways, closets, sunrooms — AFCI protected	NEC 210.12(A)	P	F	NA
<input type="checkbox"/> AFCI breakers/outlets trip on AFCI tester	NEC 210.12	P	F	NA

5C — POLARITY, GROUNDING & GENERAL

<input type="checkbox"/> All receptacles tested — correct polarity (hot left/neutral right)	NEC 200.11	P	F	NA
<input type="checkbox"/> All receptacles tested — grounded (3-slot shows ground)	NEC 250.130	P	F	NA
<input type="checkbox"/> No open grounds on 3-prong receptacles (except GFCI-labeled)	NEC 406.4	P	F	NA

<input type="checkbox"/> Two-prong ungrounded receptacles — noted and reported	NEC 406.4	P	F	NA
<input type="checkbox"/> Receptacles secure in boxes, no excessive gap at wall	NEC 406.5	P	F	NA
<input type="checkbox"/> Tamper-resistant receptacles in all new/replaced locations	NEC 406.12	P	F	NA
<input type="checkbox"/> Outdoor receptacles — weatherproof in-use cover plates	NEC 406.9(B)	P	F	NA
<input type="checkbox"/> Countertop receptacle spacing — no point > 2 ft from outlet	NEC 210.52(C)	P	F	NA
<input type="checkbox"/> Kitchen island receptacles present (if > 12 in. × 24 in.)	NEC 210.52(C)(2)	P	F	NA
<input type="checkbox"/> General wall receptacle spacing — no point > 6 ft from outlet	NEC 210.52(A)	P	F	NA

5D — 20-AMP DEDICATED CIRCUITS

<input type="checkbox"/> Kitchen small appliance circuits — minimum two 20A circuits	NEC 210.11(C)(1)	P	F	NA
<input type="checkbox"/> Laundry room — dedicated 20A circuit for washer	NEC 210.11(C)(2)	P	F	NA
<input type="checkbox"/> Bathroom — 20A circuit (for outlets only, or shared baths)	NEC 210.11(C)(3)	P	F	NA
<input type="checkbox"/> Refrigerator circuit — dedicated 20A (recommended)		P	F	NA
<input type="checkbox"/> Microwave circuit — dedicated 20A (recommended)		P	F	NA

Section 5 Notes / Photo Reference:

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Photo #

6
LIGHTING, SWITCHES & FIXTURES

PASS FAIL N/A

NEC Art. 410, 314, 404 | InterNACHI Std. 3.7

<input type="checkbox"/> All switches operable — lights activate/deactivate correctly	NEC 404.1	P	F	NA
<input type="checkbox"/> Switch boxes covered — no open knockouts or missing cover plates	NEC 314.25	P	F	NA
<input type="checkbox"/> Switches not installed in wet/damp locations without wet-rated housing	NEC 404.4	P	F	NA
<input type="checkbox"/> Three-way and four-way switching functions properly		P	F	NA
<input type="checkbox"/> Bathroom exhaust fans present and operational (fans, not just lights)	NEC 210.8	P	F	NA
<input type="checkbox"/> Recessed lighting — proper IC rating if in contact with insulation	NEC 410.116	P	F	NA
<input type="checkbox"/> Recessed lighting — airtight (AT) rating if penetrating air barrier		P	F	NA
<input type="checkbox"/> All light fixture boxes rated for fixture weight (> 50 lb req. fan/fixture box)	NEC 314.27	P	F	NA
<input type="checkbox"/> Ceiling fan boxes rated for fan support (not standard boxes)	NEC 314.27(C)	P	F	NA
<input type="checkbox"/> Pendant and chandelier fixtures secured, canopy covers box	NEC 410.36	P	F	NA
<input type="checkbox"/> Luminaires in clothes closets — LED/fluorescent only (no incandescent)	NEC 410.16	P	F	NA
<input type="checkbox"/> Clearances from combustibles maintained at fixtures	NEC 410.11	P	F	NA

- Outdoor fixtures rated for wet or damp location as appropriate NEC 410.10  P  F  NA
- Bathroom fixtures over tub/shower – wet-location rated NEC 410.10(D)  P  F  NA

Section 6 Notes / Photo Reference:

---



---



---

Photo #

7
SMOKE ALARMS & CO DETECTORS
PASS   FAIL   N/A

NFPA 72 | IRC R314 | InterNACHI Std. 3.7.11

7A – SMOKE ALARM LOCATIONS

- Smoke alarm in each sleeping room (bedroom) IRC R314.3  P  F  NA
- Smoke alarm outside each sleeping area (hallway) IRC R314.3  P  F  NA
- Smoke alarm on each level of dwelling (including basement) IRC R314.3  P  F  NA
- Ionization or photoelectric type – labeled NFPA 72 29.8  P  F  NA
- Dual-sensor alarms installed (combination type preferred)  P  F  NA
- Alarms within 3 ft of bedroom door (not in dead air spaces) NFPA 72 17.7  P  F  NA
- Not installed within 3 ft of cooking appliance (avoid nuisance trips) NFPA 72 17.7.5  P  F  NA

7B – POWER & INTERCONNECTION

- Hardwired alarms with battery backup (new construction) IRC R314.4  P  F  NA
- Alarms interconnected – if one sounds, all sound IRC R314.4  P  F  NA
- Battery-only alarms acceptable in existing pre-1992 construction IRC R314  P  F  NA
- Alarms tested – audible signal confirmed NFPA 72 14.4  P  F  NA
- Manufacturer date on alarm – replace if > 10 years old NFPA 72 14.4.4  P  F  NA

7C – CARBON MONOXIDE DETECTORS

- CO detector installed outside sleeping areas (required if fuel-burning appliance) IRC R315  P  F  NA
- CO detector within 10 ft of each sleeping room door IRC R315.2  P  F  NA
- CO detector present if attached garage IRC R315.3  P  F  NA
- CO/smoke combination unit tested and operational  P  F  NA

Section 7 Notes / Locations of Missing Alarms:

---



---



---

Photo #

**8 COMMON HAZARDS & SPECIAL CONDITIONS**  
 NEC Art. 110, 250, 300 | InterNACHI Std. 3.7

PASS FAIL N/A

[!] IMMEDIATE SAFETY CONCERNS: Any item in this section marked FAIL should be flagged as a Safety Hazard in the final report and client briefing.

8A – WIRING HAZARDS

<input type="checkbox"/> No knob-and-tube (K&T) wiring present in active use		<input type="checkbox"/> P	<input type="checkbox"/> F	<input type="checkbox"/> NA
<input type="checkbox"/> K&T if present – not covered with insulation (fire hazard)	NEC 394.12	<input type="checkbox"/> P	<input type="checkbox"/> F	<input type="checkbox"/> NA
<input type="checkbox"/> Aluminum branch circuit wiring (pre-1972) – CO/ALR devices, anti-ox compound	NEC 110.14	<input type="checkbox"/> P	<input type="checkbox"/> F	<input type="checkbox"/> NA
<input type="checkbox"/> No DIY/amateur splices outside junction boxes	NEC 300.15	<input type="checkbox"/> P	<input type="checkbox"/> F	<input type="checkbox"/> NA
<input type="checkbox"/> No open/uncovered junction boxes	NEC 314.25	<input type="checkbox"/> P	<input type="checkbox"/> F	<input type="checkbox"/> NA
<input type="checkbox"/> No cloth-insulated wiring in contact with heat sources		<input type="checkbox"/> P	<input type="checkbox"/> F	<input type="checkbox"/> NA
<input type="checkbox"/> No exposed, unprotected wiring in living spaces	NEC 300.4	<input type="checkbox"/> P	<input type="checkbox"/> F	<input type="checkbox"/> NA
<input type="checkbox"/> No extension cords used as permanent wiring	NEC 400.8	<input type="checkbox"/> P	<input type="checkbox"/> F	<input type="checkbox"/> NA
<input type="checkbox"/> No multi-outlet adapters overloading single receptacle		<input type="checkbox"/> P	<input type="checkbox"/> F	<input type="checkbox"/> NA

8B – PANEL & SERVICE HAZARDS

<input type="checkbox"/> No double-lugging on single-lug breakers	NEC 110.3(B)	<input type="checkbox"/> P	<input type="checkbox"/> F	<input type="checkbox"/> NA
<input type="checkbox"/> No oversized breakers protecting undersized conductors	NEC 240.4	<input type="checkbox"/> P	<input type="checkbox"/> F	<input type="checkbox"/> NA
<input type="checkbox"/> No missing breaker fillers / open slots in panel	NEC 408.7	<input type="checkbox"/> P	<input type="checkbox"/> F	<input type="checkbox"/> NA
<input type="checkbox"/> No evidence of prior flooding/water intrusion in panel		<input type="checkbox"/> P	<input type="checkbox"/> F	<input type="checkbox"/> NA
<input type="checkbox"/> No Federal Pacific (Stab-Lok) or Zinsco panel – (see Sec. 2E)		<input type="checkbox"/> P	<input type="checkbox"/> F	<input type="checkbox"/> NA
<input type="checkbox"/> No Pushmatic panel present (limited replacement parts)		<input type="checkbox"/> P	<input type="checkbox"/> F	<input type="checkbox"/> NA

8C – GROUNDING & BONDING HAZARDS

<input type="checkbox"/> No floating neutrals (neutral not bonded at main panel)	NEC 250.28	<input type="checkbox"/> P	<input type="checkbox"/> F	<input type="checkbox"/> NA
<input type="checkbox"/> No missing grounding electrodes	NEC 250.50	<input type="checkbox"/> P	<input type="checkbox"/> F	<input type="checkbox"/> NA
<input type="checkbox"/> No reversed polarity outlets present	NEC 200.11	<input type="checkbox"/> P	<input type="checkbox"/> F	<input type="checkbox"/> NA
<input type="checkbox"/> No open grounds on grounded-type receptacles	NEC 406.4	<input type="checkbox"/> P	<input type="checkbox"/> F	<input type="checkbox"/> NA

8D – ADDITIONAL OBSERVATIONS

<input type="checkbox"/> _____ (Inspector observation)		<input type="checkbox"/> P	<input type="checkbox"/> F	<input type="checkbox"/> NA
<input type="checkbox"/> _____ (Inspector observation)		<input type="checkbox"/> P	<input type="checkbox"/> F	<input type="checkbox"/> NA
<input type="checkbox"/> _____ (Inspector observation)		<input type="checkbox"/> P	<input type="checkbox"/> F	<input type="checkbox"/> NA
<input type="checkbox"/> _____ (Inspector observation)		<input type="checkbox"/> P	<input type="checkbox"/> F	<input type="checkbox"/> NA

\_\_\_\_\_ (Inspector observation)

P  F  NA

Section 8 Notes / Hazard Documentation:

Photo #

# Inspection Summary Report

Single-Phase Residential Electrical System

Property: \_\_\_\_\_ Date: \_\_\_\_\_  
 Inspector: \_\_\_\_\_ License #: \_\_\_\_\_

§	Section	Code Ref	# Items Pass	# Items Fail	# Items N/A	Safety Hazard?
1	Service Entrance & Meter Base	NEC Art. 230	_____	_____	_____	<input type="checkbox"/> Yes <input type="checkbox"/> No
2	Main Service Panel	NEC Art. 408, 230, 240	_____	_____	_____	<input type="checkbox"/> Yes <input type="checkbox"/> No
3	Grounding & Bonding	NEC Art. 250	_____	_____	_____	<input type="checkbox"/> Yes <input type="checkbox"/> No
4	Branch Circuits & Wiring	NEC Art. 210, 334	_____	_____	_____	<input type="checkbox"/> Yes <input type="checkbox"/> No
5	Receptacles & Outlets	NEC Art. 210.8, 210.52	_____	_____	_____	<input type="checkbox"/> Yes <input type="checkbox"/> No
6	Lighting, Switches & Fixtures	NEC Art. 410, 404	_____	_____	_____	<input type="checkbox"/> Yes <input type="checkbox"/> No
7	Smoke Alarms & CO Detectors	NFPA 72 / IRC R314	_____	_____	_____	<input type="checkbox"/> Yes <input type="checkbox"/> No
8	Common Hazards & Special Conditions	NEC Art. 110, 300	_____	_____	_____	<input type="checkbox"/> Yes <input type="checkbox"/> No
TOTALS			_____	_____	_____	

Overall System Condition:  Satisfactory  Marginal - Monitor  Deficient - Repair Needed  Safety Hazard - Immediate Action

### Safety Deficiencies & Immediate Concerns

Item #	Location	Description of Deficiency	Severity	Photo #
1			<input type="checkbox"/> Saf <input type="checkbox"/> Maj <input type="checkbox"/> Min	
2			<input type="checkbox"/> Saf <input type="checkbox"/> Maj <input type="checkbox"/> Min	
3			<input type="checkbox"/> Saf <input type="checkbox"/> Maj <input type="checkbox"/> Min	
4			<input type="checkbox"/> Saf <input type="checkbox"/> Maj <input type="checkbox"/> Min	
5			<input type="checkbox"/> Saf <input type="checkbox"/> Maj <input type="checkbox"/> Min	
6			<input type="checkbox"/> Saf <input type="checkbox"/> Maj <input type="checkbox"/> Min	
7			<input type="checkbox"/> Saf <input type="checkbox"/> Maj <input type="checkbox"/> Min	
8			<input type="checkbox"/> Saf <input type="checkbox"/> Maj <input type="checkbox"/> Min	

Inspector Recommendations & Next Steps

Recommendations:

---

---

---

---

---

Photo #

Inspector Signature: \_\_\_\_\_ Date: \_\_\_\_\_ Client Initials: \_\_\_\_\_

Disclaimer: This checklist is a field reference tool for licensed home inspectors. It is not a substitute for the full National Electrical Code (NEC), applicable local amendments, or InterNACHI Standards of Practice. Inspectors should verify all applicable code editions adopted by the local authority having jurisdiction (AHJ). NEC references are to the 2023 edition unless otherwise noted.