

TRANSFORMER INSPECTION REPORT

Commercial / Industrial · All Transformer Types
NFPA 70B · IEEE C57.12 · IEC 60076 · OSHA 1910.269 ·
NEC 250.30 / 450.10

SECTION 1 – JOB & SITE IDENTIFICATION Complete before beginning inspection

Inspection Date: MM/DD/YYYY Time of Inspection: HH:MM AM PM Permit / Work Order #: _____

Inspector Name: _____ Company / Firm: reports-inc.com License #: _____

Client / Owner: _____ Property Address: _____ Unit #: _____

Transformer Location: Vault / Pad / Pole / Indoor GPS Coordinates: _____ Weather Conditions: _____

Transformer ID / Asset #: _____ Utility Account #: _____ Circuit / Feeder ID: _____

Nameplate kVA Rating: _____ Primary Voltage: kV Secondary Voltage: V

Cooling Class: ONAN / ONAF / OFAF Insulation Class: _____ Year Manufactured: _____

Service Voltage Configuration: Delta / Wye / Zig-Zag Tap Setting: _____ Load at Inspection: % rated

LEGEND:

- **Pass** — Item meets applicable standard
- **Fail** — Deficiency found; corrective action required
- **N/A** — Not applicable to this installation
- RED TEXT** — Critical safety item

SECTION 2 – ADMINISTRATIVE & IDENTIFICATION Pre-inspection documentation and site data

Inspection Item	Result / Status
<input type="checkbox"/> Inspection work order / permit number verified [OSHA 1910.269]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Transformer nameplate data recorded (kVA, voltage, impedance, serial) [IEEE C57.12]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Transformer ID tag / asset number legible and matches records [NEC 450.10]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Manufacturer, model, and year of manufacture recorded [IEEE C57.12]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Transformer type confirmed (liquid-filled, dry-type, pad-mount, substation) [IEC 60076]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Voltage ratings (primary / secondary) verified against drawings [IEEE C57.12]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Cooling class designation verified (ONAN, ONAF, OFAF, etc.) [IEC 60076]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Location map / site plan on file	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Prior inspection records reviewed for recurring deficiencies [NFPA 70B]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Lockout/Tagout (LOTO) procedures verified before energized approach [OSHA 1910.269]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Arc-flash hazard analysis / PPE level confirmed [NFPA 70B]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A

Findings / Observations:

Corrective Actions Required:

SECTION 3 – PHYSICAL CONDITION & ENCLOSURE Structural, environmental, and weathering assessment

Inspection Item	Result / Status
<input type="checkbox"/> Tank / enclosure free of dents, deformation, or impact damage [IEEE C57.12]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Paint / coating intact – no peeling, blistering, or bare metal exposed [NFPA 70B]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Active corrosion (rust, oxidation, pitting) noted and located [NFPA 70B]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Enclosure welds and seams free of cracks [IEEE C57.12]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Pad-mount cabinet doors close, latch, and lock properly [NEC 450.10]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Ventilation openings clear of debris and obstructions [NFPA 70B]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Drainage / weep holes functioning [IEC 60076]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Ground-level clearances comply with NEC 450.10 (12 in. min. ventilation sides) [NEC 450.10]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Vegetation / debris cleared within 3 ft of unit [NFPA 70B]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Unit leveling adequate (< 1.5° tilt for liquid-filled) [IEC 60076]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Evidence of animal intrusion (nesting, burrowing, chew marks) [NFPA 70B]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A

Findings / Observations:

Corrective Actions Required:

SECTION 4 – OIL / LIQUID INSULATION SYSTEMS Liquid level, quality, leaks, and containment – IEC 60076-1, IEEE C57.12

Inspection Item	Result / Status
<input type="checkbox"/> Oil / liquid level within normal range on sight glass [IEEE C57.12]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Sight glass clean, legible, and free of cracks [IEC 60076]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Oil color normal (clear to light yellow – not dark or cloudy) [NFPA 70B]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Active oil leaks present at tank seams, gaskets, or fittings [IEEE C57.12]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Old leak staining noted (location recorded below) [NFPA 70B]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Drain valve capped and free of leaks [IEC 60076]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A

<input type="checkbox"/> Pressure relief device intact and unobstructed [IEEE C57.12]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Conservator / expansion tank (if equipped) at correct level [IEC 60076]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Buchholz relay (if equipped) checked for gas accumulation [IEC 60076]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Oil containment / spill containment basin adequate [OSHA 1910.269]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Sampling port / valve accessible for dielectric testing [IEEE C57.12]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Silica gel breather (if equipped) – color indicates moisture status [NFPA 70B]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Last oil sample date and dielectric strength result on file [NFPA 70B]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A

Findings / Observations:

Corrective Actions Required:

SECTION 5 – TEMPERATURE MONITORING Thermal performance and overtemperature protection

Inspection Item	Result / Status
<input type="checkbox"/> Oil temperature gauge readable and within rated limits [IEC 60076]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Winding temperature indicator (WTI) present and functional [IEEE C57.12]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Thermal overload trip settings verified against rated temp rise [NFPA 70B]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> High-temperature alarm contact functional (where installed) [IEEE C57.12]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Infrared / thermographic inspection performed (attach report) [NFPA 70B]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Hot-spot temperature calculated or measured \leq rated limit [IEC 60076]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Cooling fans / radiators operational (ONAF / OFAF units) [IEC 60076]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Fan motor controls and overload relays functional [NFPA 70B]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Ambient temperature at time of inspection recorded [IEEE C57.12]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Load current at time of inspection recorded (% of rated) [NFPA 70B]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A

Findings / Observations:

Corrective Actions Required:

SECTION 6 – BUSHINGS & ELECTRICAL CONNECTIONS HV/LV bushings, terminations, conductors – IEEE C57.12, NFPA 70B

Inspection Item	Result / Status
-----------------	-----------------

<input type="checkbox"/> HV bushings free of cracks, chips, or carbon tracking [IEEE C57.12]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> LV bushings free of cracks, chips, or carbon tracking [IEEE C57.12]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Bushing oil levels visible and adequate (where applicable) [IEC 60076]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Bushing gaskets intact — no oil seepage at bushing base [IEEE C57.12]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> HV terminations tight, no discoloration or arcing evidence [NFPA 70B]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> LV terminations tight, no discoloration or arcing evidence [NFPA 70B]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Conductor sizing verified for transformer kVA and service [NEC 450.10]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Conductor insulation intact — no cuts, abrasions, or heat damage [NFPA 70B]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Neutral conductor connections secure (primary and secondary) [NEC 250.30]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Tap-changer / DETC position set correctly and locked [IEEE C57.12]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> No evidence of insulation flashover on bushing surfaces [IEEE C57.12]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Conduit entries sealed to prevent moisture intrusion [NFPA 70B]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A

Findings / Observations:

Corrective Actions Required:

SECTION 7 — GROUNDING & BONDING SYSTEMS NEC 250.30, OSHA 1910.269 compliance

Inspection Item	Result / Status
<input type="checkbox"/> System grounding conductor connected at separately derived system source [NEC 250.30]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Grounding electrode system installed and connected [NEC 250.30]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Equipment grounding conductor (EGC) present and sized per NEC 250.122 [NEC 250.30]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Ground rod / electrode connections tight and corrosion-free [NEC 250.30]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Transformer tank / enclosure bonded to grounding electrode system [NEC 250.30]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Ground fault current path continuous and low-impedance [OSHA 1910.269]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> No multiple neutral-to-ground bonds on load side of transformer [NEC 250.30]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Grounding conductor routed free of mechanical damage [NEC 250.30]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Ground resistance test result on file (target < 25 ohms) [IEEE C57.12]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Lightning arrester / surge arrester installed and bonded (if required) [IEEE C57.12]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Arrester ground lead connected to tank ground and grounding electrode [IEEE C57.12]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A

Findings / Observations:

Corrective Actions Required:

SECTION 8 — PROTECTIVE DEVICES & OVERCURRENT PROTECTION Primary / secondary protection, relays, fuses, interrupters

Inspection Item	Result / Status
<input type="checkbox"/> Primary fuses / fuse cutouts present and correct ampere rating [NEC 450.10]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Secondary overcurrent protection within 125% of FLA (or per NEC 450.3) [NEC 450.10]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Fuse links / elements intact — no evidence of operation [NFPA 70B]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Expulsion fuse tubes free of carbon, blowout damage [NFPA 70B]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Protective relay settings match protection coordination study [IEEE C57.12]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Differential relay (if equipped) tested and functional [IEEE C57.12]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Overcurrent / ground fault relay test dates on file [NFPA 70B]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Sudden pressure relay (if equipped) checked and functional [IEEE C57.12]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Disconnect switch / circuit breaker operates smoothly [NFPA 70B]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Interrupter / recloser sequence settings correct [IEEE C57.12]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Wiring to control panel / SCADA intact and labeled [NFPA 70B]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A

Findings / Observations:

Corrective Actions Required:

SECTION 9 — SAFETY FEATURES, SIGNAGE & LABELING NEC 450.10, NFPA 70B, OSHA 1910.269 safety markings

Inspection Item	Result / Status
<input type="checkbox"/> DANGER / HIGH VOLTAGE warning signs posted on all accessible sides [OSHA 1910.269]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Voltage level clearly posted (primary and secondary) [NEC 450.10]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Arc-flash hazard label present (NFPA 70E compliant) [NFPA 70B]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Transformer ID / circuit designation label legible [NEC 450.10]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Fire rating / PCB content label present (if liquid-filled) [OSHA 1910.269]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Emergency contact / utility information posted [OSHA 1910.269]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A
<input type="checkbox"/> Grounding electrode conductor labeled at panel end [NEC 250.30]	<input type="radio"/> Pass <input type="radio"/> Fail <input type="radio"/> N/A

- Safety interlock / key-exchange system functional (where installed) [OSHA 1910.269] Pass Fail N/A
- Transformer room / vault fire suppression system functional [NFPA 70B] Pass Fail N/A
- Portable fire extinguisher within 30 ft and accessible [NFPA 70B] Pass Fail N/A
- Emergency lighting functional in transformer vault [NFPA 70B] Pass Fail N/A
- Dry-type transformer rated room meets 'Fire-Resistant Construction' (NEC 450.21) [NEC 450.10] Pass Fail N/A

Findings / Observations:

Corrective Actions Required:

SECTION 10 – PHOTO DOCUMENTATION Attach digital photos or paste/reference below

[Photo] Overview / General	[Photo] Nameplate	[Photo] HV Bushings
[Photo] LV Bushings	[Photo] Oil Sight Glass	[Photo] Temperature Gauge
[Photo] Grounding System	[Photo] Protective Devices	[Photo] Condition Defect
[Photo] Condition Defect 2	[Photo] Labeling / Signs	[Photo] Additional

Photo Notes / Captions:

SECTION 11 – OVERALL CONDITION RATING & SUMMARY Circle one rating for each system

Overall Transformer Condition	1 <small>Critical</small>	2 <small>Poor</small>	3 <small>Fair</small>	4 <small>Good</small>	5 <small>Excellent</small>
Oil / Liquid System	1 <small>Critical</small>	2 <small>Poor</small>	3 <small>Fair</small>	4 <small>Good</small>	5 <small>Excellent</small>
Thermal / Temperature System	1 <small>Critical</small>	2 <small>Poor</small>	3 <small>Fair</small>	4 <small>Good</small>	5 <small>Excellent</small>
Bushings & Electrical Connections	1 <small>Critical</small>	2 <small>Poor</small>	3 <small>Fair</small>	4 <small>Good</small>	5 <small>Excellent</small>
Grounding & Bonding System	1 <small>Critical</small>	2 <small>Poor</small>	3 <small>Fair</small>	4 <small>Good</small>	5 <small>Excellent</small>

Protective Devices	1 <small>Critical</small>	2 <small>Poor</small>	3 <small>Fair</small>	4 <small>Good</small>	5 <small>Excellent</small>
Safety Signage & Labeling	1 <small>Critical</small>	2 <small>Poor</small>	3 <small>Fair</small>	4 <small>Good</small>	5 <small>Excellent</small>

Executive Summary / Key Findings:

Immediate Action Items (Safety):

Recommended Maintenance / Next Steps:

Priority Level:	<input type="radio"/> IMMEDIATE – Unsafe, shut down	<input type="radio"/> URGENT – Repair within 30 days	<input type="radio"/> ROUTINE – Schedule maintenance	<input type="radio"/> SATISFACTORY – No action needed
------------------------	---	--	--	---

SECTION 12 – CERTIFICATIONS & SIGNATURES

The undersigned certify that this inspection was performed in accordance with applicable standards including NFPA 70B, IEEE C57.12.00, IEC 60076, OSHA 1910.269, NEC Article 250 and 450, and that the findings recorded herein accurately represent the condition of the equipment at the time of inspection.

Inspecting Technician / Inspector: Print Name Signature: _____ Date: MM/DD/YYYY

Reviewing Engineer / Supervisor: Print Name Signature: _____ Date: MM/DD/YYYY

Client / Owner Representative: Print Name Signature: _____ Date: MM/DD/YYYY

Inspector License / Cert #: State / ANSI / InterNACHI Certifying Body: _____ Expiration Date: MM/YYYY

Referenced Standards: NFPA 70B-2023 Recommended Practice for Electrical Equipment Maintenance · IEEE C57.12.00-2021 Standard for Liquid-Immersed Distribution, Power, and Regulating Transformers · IEC 60076-1:2011 Power Transformers · OSHA 1910.269 Electric Power Generation, Transmission, and Distribution · NEC 250.30 Grounding Separately Derived Systems · NEC 450.10 Marking of Transformers